



Product Service

Compliance Document

No. D 119897 0004 Rev. 01

Holder of Certificate: **Hanersun Energy Co., Ltd.**10F, B4 Block, No.19 Suyuan Avenue
Jiangning District
211100 Nanjing
PEOPLE'S REPUBLIC OF CHINA**Product:** **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-crystalline Silicon Photovoltaic module**Model(s):** **HN21N-66HTxxxW, xxx=670-715 in steps of 5**
HN21N-60HTxxxW, xxx=610-650 in steps of 5
xxx is standing for rated output power at STC**Parameters:**
Fire Safety Class: Class C according to UL790.
Safety Class: Class II
Max. system voltage: 1500V DC or 1000V DC
Construction: Framed, with Junction box,
Cable and Connectors.
Remark: Modules listed above comply with the requirements of
being non-sensitive to LETID.**Tested** IEC TS 63342:2022
according to:

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062424506-01**Date,** 2024-12-09

(Zhulin Zhang)